

+

PUBLIC NOTIFICATION MONITORING/REPORTING REQUIREMENTS NOT MET

Water System Name: REMERTON WATER SYSTEM

County: Lowndes

Date of Release: 28 July 28, 2010

Contact Person: RONALD WOODS

Phone: (229) 247-2320

Mailing Address: 1757 POPLAR ST.

City: REMERTON **State:** Georgia **Zip:** 31601

Violation: The Remertom Water System exceeded the Maximum contaminant level (MCL) for Haloacetic Acid (HAA5) for compliance period 10/01/2009 to 06/30/2010. Violation ID:2010-120,121,122.

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing to correct this situation.

We conduct quarterly monitoring for Haloacetic Acids (HAA5). The running arithmetic average of the last three quarters were 0.070 mg/l, 0.078 mg/l, 0.079 mg/l respectively. The maximum contaminant level (MCL) established by USEPA is 0.060 mg/L.

Some people who drink water – containing haloacetic acid in excess of the maximum contaminant level (MCL) over many years experience problems with their liver, kidneys, or central nervous system, and may have an increase risk of getting cancer.

What should you do?

There is nothing you need to do at this time. This violation does not pose a threat to the quality of the water supplied. Residents should not be alarmed and do not need to seek alternative water supplies. The supplier is taking corrective actions to insure that adequate monitoring and reporting will be maintained.

What is being done?

The flushing program for the area is being stepped up to more frequent flushing and chlorine injection is being closely monitored. Also chemical treatment of water is being changed from aquadene and biopurge to sea quest. This should help lower the amount of chlorine being injected into system.

For more information, please contact the above person.